



Standards:

- ·BS 5266 Part 1:2005, BS EN 60598-2-22:2002, ·FSD PPA 104(A) 4th Revision.

Features:

- · Suitable for MR16 12V 25W/50W/75W/100W Tungsten Halogen.
- · Slim size remote metal box with white powder coated.
- · For long extended services life and highly reliability quality components.
- · Red and Green LED to indicate mains supply and charge are functioning.
- Test Button to allow easy checking of luminaries operation.

Specification:

· Remote metal box, self-contained, non-maintained type, emergency battery pack with automatic changeover device for minimum 2 or 3 hours battery back up.

Model

Battery

Line Voltage

Recharge Period

Battery Type

Mode of Operation

Emergency Output

Emergency Duration

ALS-1250-2

Sealed Lead Acid

Sealed Ni-Cd/Ni-Mh are available Maintained Type

*Non-Maintain type are available Minimum 50% ***Adjustable

2 Hours

12V 8.0 Ah

A/C 220V 50Hz +/-10%

12 Hours for 2 Hours Discharge ***Option will be available upon request

N



***3 Hours are available