



Standards:

- BS 5266 Part 1:2005,
- BS EN 60598-2-22:2002,
- FSD PPA 104(A) 4th Revision.

Features:

- Lamp Source: OPTILED 22.5W LED tubular tube.
- Red LED to indicate mains supply and healthy charging status.
- Test Button to allow easy checking of luminaries operation.
- Optional Metal housing constructed of galvanized steel with EPOXY powder coating.

Specification:

- Maintained / Non-maintained type, Self-contained, automatic changeover device for minimum 2 or 3 hours battery back up.

Model	ALS-2C-LED-220-45
Complete Set Model	ALS-2C-LED-220-45 + FB140
Suitable to	OPTILED 22.5W LED Tubular
Battery Type	Sealed Ni-Cad <small>***Sealed Ni-Mh are available</small>
Mode of Operation	Maintained Type <small>***Non-maintained type are available</small>
Emergency Output	90% <small>***Adjustable</small>
Emergency Duration	2 Hours <small>***3 Hours are available</small>
Battery	12V 5.5Ah
Line Voltage	A/C 220V 50Hz +/-10%
Operation Temperature	0 - 50°C
Batten Size (mm)	1,230L x 50H x 60D
Recharge Period	12 (*24)Hours for 1 (*2) Hours Discharge <small>***Options will be available upon request *Metal housing are available</small>

