



Standards:

- BS 5266 Part 1:2005,
- BS EN 60598-2-22:2002,
- FSD PPA 104(A) 4th Revision.

Features:

- Lamp Source: T5 / T5HO.
- Red LED to indicate mains supply and healthy charging status.
- Test Button to allow easy checking of luminaries operation.
- Optional Metal housing constructed of galvanized steel with EPOXY powder coating.

Specification:

- Maintained / Non-maintained type, Self-contained, automatic changeover device for minimum 2 or 3 hours battery back up.

Model	ALS-2C-114W	ALS-2C-121W	ALS-2C-128W	ALS-2C-135W
Suitable to	T5: 14W	T5: 21W	T5: 28W	T5: 35W
Battery Type	Sealed Ni-Cad <small>***Sealed Ni-Mh are available</small>			
Mode of Operation	Maintained Type <small>***Non-maintained type are available</small>			
Emergency Output	0.25 BLF <small>***Adjustable</small>			
Emergency Duration	2 Hours <small>***3 Hours are available</small>			
Battery	6V 2.0Ah	9.6V 2.0Ah	9.6V 2.0Ah	12V 2.0Ah
Line Voltage	A/C 220V 50Hz +/-10%			
Operation Temperature	0 - 50°C			
Recharge Period	12 Hours for 2 Hours Discharge <small>***Options will be available upon request *Metal housing are available</small>			