



**Specification:**

- Self-contained, maintained type, automatic changeover device for minimum 2 or 3 hours battery back up.

**Standards:**

- BS 5266 Part 1:2005,
- BS EN 60598-2-22:2002,
- BS5499-3:2002,
- FSD PPA 104(A) 4<sup>th</sup> Revision,
- FSD COP Clause 5.10 EXIT Sign.

**Features:**

- Lamp Source: T5 / T5HO.
- Red LED to indicate mains supply and healthy charging status.
- Test Button to allow easy checking of luminaries operation.
- Optional Metal housing constructed of galvanized steel with EPOXY powder coating.

Model	ALS-2C-114W + FB114 / 214	ALS-2C-121W + FB121 / 221	ALS-2C-128W + FB128 / 228	ALS-2C-135W + FB135 / 235
Suitable to	T5: 14W	T5: 21W	T5: 28W	T5: 35W
Battery Type	Sealed Ni-Cad <small>***Sealed Ni-Mh are available</small>			
Mode of Operation	Maintained Type <small>***Non-maintained type are available</small>			
Emergency Output	0.25 BLF <small>***Adjustable</small>			
Emergency Duration	2 Hours <small>***3 Hours are available</small>			
Battery	6V 2.0Ah	9.6V 2.0Ah	9.6V 2.0Ah	12V 2.0Ah
Line Voltage	A/C 220V 50Hz +/-10%			
Operation Temperature	0 - 50°C			
Recharge Period	12 Hours for 2 Hours Discharge <small>***Options will be available upon request</small> <small>*Metal housing are available</small>			